

CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Audit Information:

Utility: Monrovia PWS ID: 1910090
System Type: Potable Audit Period: Calendar 2016
Utility Representation: Paul Zampielo, Todd Hull, Lauren Marshall
Validation Call Date: 8/21/2017 Call Time: 1:00 pm Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 57 Data Validity Band (Level): Band III (51-70)
ILI: 0.90 Real Loss: 17.40 (gal/conn/day) Apparent Loss: 14.10 (gal/conn/day)
Non-Revenue Water as a Percentage of Operating Costs: 3.3%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Tory Wagoner Validator Qualifications: Contractor for CA-NV AWWA Water Loss TAP

Validator Provided